16.03.2018

10:23:48h

SCHMERSAL

Datasheet - AZ 15 ZVK

Safety switch with separate actuator / AZ 15

Preferred typ



- Thermoplastic enclosure
- Double-insulated 🗆
- Long life
- 52 mm x 75 mm x 30 mm
- Multiple coding
- Large wiring compartment
- · High level of contact reliability with low voltages and currents
- Slotted holes for adjustment, circular holes for location
- Insensitive to soiling
- 3 cable entries M 16 x 1.5

(Minor differences between the printed image and the original product may exist!)


Ordering details

Product type description
Article number
Strobe lamp
eCl@ss

Approval

Approval





Classification

Standards B10d Normally-closed contact (NC) Mission time notice

EN ISO 13849-1 2.000.000 20 Years MTTF_d = $\frac{B_{10d}}{0,1 \times n_{op}}$

 $n_{op} = \frac{d_{op} \times h_{op} \times 3600 \text{ s/h}}{t_{oycle}}$

Global Properties

Permanent light	AZ 15
Standards	EN 60947-5-1, BG-GS-ET-15
Compliance with the Directives (Y/N) CE	Yes
suitable for elevators (Y/N)	Yes
Materials	
- Material of the housings	Plastic,, glass-fibre reinforced thermoplastic self-extinguishing
- Material of the contacts	Silver
Housing coating	None
Weight	100
- Material of the contacts Housing coating	Silver None

Mechanical data

Design of electrical connection	Screw connection
Cable section	
- Min. Cable section	0,75
- Max. Cable section	2.5
Mechanical life	> 1.000.000 operations
notice	All indications about the cable section are including the conductor ferrules.
higher Latching force (Y/N)	No
With ejection force (Y/N)	Yes
Positive break force	10
positive break travel	8
Actuating speed	2

Ambient conditions

Ambient temperature	
- Min. environmental temperature	-30
- Max. environmental temperature	+80
Protection class	IP67 to IEC/EN 60529

Electrical data

Design of control element	Opener (NC)
Switching principle	Creep circuit element
Number of auxiliary contacts	0
Number of safety contacts	1
Rated impulse withstand voltage	6
Rated insulation voltage	500
Thermal test current	10 A
Utilisation category	AC-15: 230 V / 4 A, DC-13: 24 V / 4 A
Max. fuse rating	6 A gG D-fuse

ATEX

Explosion protection categories for gases	None
Explosion protected category for dusts	None

Dimensions

- Width of sensor	52
- Height of sensor	75
- Length of sensor	30

Included in delivery


Actuators must be ordered separately.

Diagram



Note Diagram → positive break NC contact active no active Normally-open contact Normally-closed contact

Switch travel diagram




Ordering suffix

The applicable ordering suffix is added at the end of the part number of the safety switch. Order example: AZ 15 ZVK-1637

...-1637

0,3 µm gold-plated contacts



Cannot be retrofitted

Documents

Operating instructions and Declaration of conformity (pt) 433 kB, 25.05.2010 Code: mrl_az15-16_pt

Operating instructions and Declaration of conformity (pt) 287 kB, 08.07.2016 Code: mrl_az15-16_pt

Operating instructions and Declaration of conformity (de) 267 kB, 04.03.2016 Code: mrl_az15-16_de

Operating instructions and Declaration of conformity (fr) 284 kB, 27.04.2016 Code: mrl_az15-16_fr

Operating instructions and Declaration of conformity (jp) 564 kB, 23.08.2016 Code: mrl_az15-16_jp

Operating instructions and Declaration of conformity (es) 281 kB, 09.03.2016 Code: mrl_az15-16_es

Operating instructions and Declaration of conformity (en) 283 kB, 04.03.2016 Code: mrl_az15-16_en

Operating instructions and Declaration of conformity (nl) 266 kB, 02.07.2013 Code: mrl_az15-16_nl

Operating instructions and Declaration of conformity (it) 275 kB, 15.04.2016 Code: mrl_az15-16_it

BG-test certificate (en) 135 kB, 18.11.2014 Code: z_z15p02


BG-test certificate (de) 138 kB, 18.11.2014 Code: z_z15p01

CCC certification (cn) 3 MB, 18.10.2017 Code: q_175p03

CCC certification (en) 3 MB, 29.08.2017 Code: q_175p02 EAC certification (ru) 1 MB, 15.03.2018 Code: q_avp04

EAC certification (ru) 844 kB, 05.10.2015 Code: q_6037p17_ru

Images



Dimensional drawing (basic component)

K.A. Schmersal GmbH & Co. KG, Möddinghofe 30, D-42279 Wuppertal The data and values have been checked throroughly. Technical modifications and errors excepted. Generiert am 16.03.2018 - 10:23:48h Kasbase 3.3.0.F.64I